



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

DISTRICT WATER TESTING LABORATORY

No. 471 & 472, Bharathiyar Complex, Avinashi Road,
Tiruppur – 641602.

Phone: 0421 - 2245201

E-mail: labtpr@gmail.com

TEST REPORT


Doc.No: DWTL/FORM/7.8/01

Sample / Lab No:	TR/2026/015-2	Report Issue Date :	12.02.2026
Invoice Details:	3244/Dt.10.02.2026/ Amt.Rs.1,652/-		


S.No	Parameters	Test Method	Unit	Result	Specification as per IS 10500 : 2012	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	Appearance	Physical observation	--	Clear	-	-
2	Colour	IS 3025-Part 4	Hazen	< 2	5	25
3	Odour	IS 3025-Part 5	--	Agreeable	Agreeable	Agreeable
4	Turbidity	IS 3025-Part 10	NTU	< 0.5	1	5
5	Total Dissolved Solids	IS 3025-Part 16	mg/L	271	500	2000
6	Conductivity	IS 3025-Part 14	μS/cm	387	-	-
7	P – Alkalinity as CaCO ₃	IS 3025–Part 23-1983	mg/L	NIL	-	-
8	Calcium as Ca	IS 3025–Part 40	mg/L	34	75	200
9	Magnesium as Mg	IS 3025–Part 46	mg/L	11	30	100
10	Iron as Fe	IS 3025–Part 53	mg/L	< 0.1	0.3	1
11	Manganese as Mn	IS 3025–Part 59	mg/L	< 0.05	0.1	0.3
12	Ammonia as NH ₃	IS 3025–Part 34	mg/L	< 0.5	0.5	0.5
13	Nitrite as NO ₂	IS 3025–Part 34	mg/L	< 0.01	-	-
14	Total Phosphate as PO ₄	IS 3025–Part 31	mg/L	< 0.1	-	-
15	Residual Chlorine	IS 3025–Part 26	mg/L	0.2	0.2	1.0
16	Fecal Coliform	IS 1622	CFU/100ml	0 / 100ml	0 / 100ml	0/100ml

Remarks : The Tested sample conformed IS:10500:2012 Drinking water specification with respect to above tested Parameters.

..... End of the Report....


PRINCIPAL
Vivekananda Global Academy
(CBSE)
Palladam Road, Ganapathipalayam Pirivu,
TIRUPUR - 641 605.


Vivekananda Global Academy
(CBSE)
(A Unit of Vivekananda Seva Trust)
Palladam Road, Ganapathipalayam Pirivu,
TIRUPUR - 641 605.
Ph: 96552 39813, 96552 39896.


Reviewed & Authorised Signatory
B .George - Junior Engineer

Note:

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

DISTRICT WATER TESTING LABORATORY

No. 471 & 472, Bharathiyar Complex, Avinashi Road,
Tiruppur - 641602.

Phone: 0421 - 2245201

E-mail: labtpr@gmail.com



TC - 15221

TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Sample / Lab No:	TR/2026/015-1	Report Issue Date :	12.02.2026
Invoice Details:	3244/Dt.10.02.2026/ Amt.Rs.1,652/-		
ULR No:	TC15221260000015F		

Client Name & Address : M/s.Vivekananda Global Academy(CBSE),
Contact No / Email.ID : Ganapathipalayam Pirivu,
Palladam Road, Tiruppur- 641 605.

Sample Name : Water- Drinking
 Sample Description : L&T Water
 Sample Code No : 015-1
 Sample Submitted by : Customer- Thiru.Varadharajan.E
 Location & Date : At M/s.Vivekananda Global Academy(CBSE) & 10.02.2026.
 Quantity of sample Received : 2 Litre
 Sample Container : Plastic - Good condition.
 Sample Condition on Receipt : Good
 Sample Received On : 10.02.2026
 Test Commenced on : 10.02.2026
 Test Completed on : 11.02.2026
 Environmental Condition : 23.0°C-27.0°C

S.No	Parameters	Test Method	Unit	Result	Specification as per IS 10500 : 2012	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	pH @ 25° C	IS 3025 Part 11-2022	--	7.91	6.5-8.5	6.5-8.5
2	Total Alkalinity as CaCO ₃	IS 3025 Part 23-2023	mg/L	109	200	600
3	Total Hardness as CaCO ₃	IS 3025 Part 21-2009 (RA:2023)	mg/L	129	200	600
4	Chloride as Cl	IS 3025-Part 32-1988 (RA:2019)	mg/L	34	250	1000
5	Sulphate as SO ₄	IS 3025-Part 24- Sec 1-2022	mg/L	22	200	400
6	Nitrate as NO ₃	IS 3025-Part 34- Sec 1-2023	mg/L	38	45	45
7	Fluoride as F	IS 3025-Part 60- Sec 1-2023	mg/L	0.4	1.0	1.5

Remarks : The Tested sample conformed IS:10500:2012 Drinking water specification with respect to above tested Parameters. End of the Report.....

[Handwritten Signature]

Reviewed & Authorised Signatory
B. George - Junior Engineer

Vivekananda Global Academy

(CBSE)

Note:

- The test results relate only to the items tested.
- The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
- Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
- The result applied to the sample as received basis.

TIRUPPUR - 641 605.
Ph: 96552 39813, 96552 39896.

Issue No./Date	01/01.07.2024	Amend. No/ Date	00/--	Page No	1 of 1
----------------	---------------	-----------------	-------	---------	--------